



EC - CERTIFICATE OF CONFORMITY

1299 - CPD - 0055

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of Communities of 22 July 1993, it has been stated that the construction product

Pillar fire hydrant, without breaking system
type: "HN1S80", outlets 2xB
DN 80, PN 16

The dry pillar fire hydrant DN 80, PN 16 is assigned for installing into outdoor water pipes for water supply intended for fire extinguishing including water assigned for human consumption, under condition, that used materials including lubricants, coming into contact with water for human consumption shall comply with the national regulations in the country of use

placed on the marked by producer

DOMEX Sp. z o.o., ul. Pieszyccka 11, 58-200 Dzierżoniów, Poland

and produced in the factory

DOMEX Sp. z o.o., ul. Pieszyccka 11, 58-200 Dzierżoniów, Poland

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body No. 1299 - Technický skúšobný ústav Piešťany, š.p. - has performed the initial type-testing for the relevant characteristics of the products, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard


EN 14384: 2005

were applied and product fulfils all the prescribed requirements.

This certificate was first issued on April 11, 2011 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Piešťany April 11, 2011




Ing. Anna ONDRÁŠIKOVÁ
Product Conformity Assessment Director

Characteristic of construction product:

1. Operational reliability

- construction, clauses: 4.2; 4.3; 4.4; 4.5*; 4.11*; 4.14; 4.17*; 4.19
- pressures, clause: 4.6
- direction of closure, clause: 4.8
- number of opening turns, clause: 4.9
- resistance of hydrant to operating loads, clause: 4.10
- hydraulic characteristics, clause: 4.20

2. Connection dimensioning, clauses: 4.12; 4.13*

3. Durability of operational reliability; resistance against corrosion, clause: 4.16

4. Durability of operational reliability; endurance, clause: 4.6.4

Properties marked with* shall be in conformity with national regulations applicable in the country of products usage or their design is approved in the country of use.



A handwritten signature in blue ink, appearing to be "Dukles".